chanhvinh.com

Certificate of Compliance

Certification Number: LR 40012-7

Revision: LR 40012-9 Date Issued: July 31, 1995

Issued to: Critchley Ltd.
Wellington House
Bath Road
Woodchester, Stroud
Glos. GL5 5EY
England

The products listed below are eligible to bear the CSA Mark.

Issued by: J Pankowski P. Eng
CSA Pointe Claire

Signature:

PRODUCTS

CLASS No 3211-07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Wiring raceway, 'Betaduct', thermoplastic either rigid PVC, any colour, or MPPO (modified polyphenylene oxide) brown, with snap-on covers, open, closed or narrow-slotted or plain.

Note: These raceways are Certified for use only as component parts of control panels and similar equipment, where the suitability of the combination has been determined by the Canadian Standards Association.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 0.6-M1982	Flammability testing of Polymeric Material
No. 14-M91	Industrial Control Equipment

DQD 507